Technical Data

Metal Switches




Series SN2


Description SN2-U1Z HW

Article number 6033121007

Operating symbol




Operating diagram






Tolerances

Operating point: ± 0,25mm; Actuating force: ± 10%





Electrical data		
Rated insulation voltage	U _i	400 VAC
Conv. thermal current	I _{the}	10A
Rated operational voltage	U_e	240V
Utilization category		AC-15, U _e /I _e 240V/3A
Direct opening action	\odot	according to IEC/EN 60947-5-1, Annex K
Short-circuit protective device		Fuse 10A gL/gG
Protection class		I

This document will not become the contractual basis; the details included herein do not constitute any descriptions of expected conditions, so that warranties/claims for defects on account of possible variations of the actual qualities from the qualities described herein are explicitly excluded. All rights reserved. Specifications subject to change without notice!

Date of issue: 26.10.2005 / Page 1 of 2 Document: 6033121007_en / Last update: 1 / 2912-05

Technical Data

Metal Switches



Mechanical data	
Enclosure	Die-cast aluminium
Cover	Sheet aluminium
Actuator	Lever (st), roller (thermoplastic)
Ambient air temperature	-30°C +80°C
Contact type	1 NC, 1 NO (Zb)
Mechanical life	10 x 10 ⁶ operating cycles
Switching frequency	≤ 100 / min.
Assembly	4 x M5
Connection	4 screw terminals (M3.5)
Conductor cross-sections	Solid: 0,5 1,5mm ²
	Litz wire with ferrules: 0.5 1.5mm ²
Cable entrance	3 x M20x1,5
Weight	≈ 0,22kg
Installation position	Operator definable
Protection type	IP65 acc. to IEC/EN 60529

Actuation

By loosening the 4 screws the actuation assembly can be rotated in 90 degree increments such that 4 actuation directions are possible. The actuation assembly is to be again fastened to the housing using the 4 screws.

Standards	VDE 0660 T100, DIN EN 60947-1, IEC 60947-1
	VDE 0660 T200, DIN EN 60947-5-1, IEC 60947-5-1
EU Conformity	C€
Approvals	_C CSA _{US} A300 (same polarity)

Notes

The degree of protection (IP code) specified applies solely to a property closed cover and the use of an equivalent cable gland with adequate cable.

This document will not become the contractual basis; the details included herein do not constitute any descriptions of expected conditions, so that warranties/claims for defects on account of possible variations of the actual qualities from the qualities described herein are explicitly excluded. All rights reserved. Specifications subject to change without notice!

Date of issue: 26.10.2005 / Page 2 of 2 Document: 6033121007_en / Last update: 1 / 2912-05