


# Plastic bodied limit switch

Series ENK

Description ENK-U1Z AHSGU-V RO50

Article number 6181135310



Electrical Data		
Rated insulation voltage	U	400 V AC
Conv. thermal current	l <sub>the</sub>	10 A
Rated operational voltage	Ue	240 V
Utilization category		AC-15, U /I 240 V / 3 A
Positive opening operation	$\ominus$	acc. to IEC/EN 60947-5-1, annex K
Short-circuit protective device		Fuse 10 A gG
Protection class		II, totally insulated

BERNSTEIN AG . Hans-Bernstein-Straße 1 . 32457 Porta Westfalica . www.bernstein.eu

Technical modifications and errors excepted.

The technical datasheet corresponds to the technical state as of 2017-04-10 and will not be removed in case of changes.

## **Technical Data**



Mechanical data			
Enclosure	Thermoplastic, glass fibre reinforced		
Cover	Thermoplastic, glass fibre reinforced		
Actuator	Turret head (Zn die-casting), lever (steel), roller (rubber)		
Ambient air temperature	-30 °C +80 °C		
Contact type	1 NC, 1NO (Zb)		
Mechanical life	1 x 10 <sup>6</sup> operating cycles		
Switching frequency	≤ 100 / min.		
Assembly	4 x M5		
Connection	4 screw connections (M3,5)		
Conductor cross-sections	Solid: 0,5 1,5 mm² or Litz wire with ferrules: 0,5 1,5 mm²		
Cable entrance	1 x cable gland M20 x 1,5 (clamping range 5-10 mm)		
Weight	≈ 0,25 kg		
Installation position	operator definable		
Protection type	IP65 acc. to EN 60529		

#### Actuation

The actuating device is preferably started from 2 sides.

By loosening the 4 screws the actuation assembly can be rotated in 90 degree increments such that 8 actuation directions are possible. The actuation assembly is to be again fastened to the housing using the 4 screws.

#### Standards

VDE 0660 T100, DIN EN 60947-1, IEC 60947-1 VDE 0660 T200, DIN EN 60947-5-1, IEC 60947-5-1

### **EU Conformity**

acc. to directive 2014/35/EU (Low-Voltage-Directive)

#### Approvals

 $_{\rm C}{\rm CSA}_{\rm US}$  A300 (same polarity) UL

#### Notes

The degree of protection (IP code) specified applies solely to a property closed cover and the use of an equivalent cable gland with adequate cable.