


# **Plastic bodied limit switch**

Series Bl2

Description BI2-U1Z AHS (GER50)

Article number 6185135101



Electrical Data		
Rated insulation voltage	Ui	400 V AC
Conv. thermal current	$I_{\text{the}}$	10 A
Rated operational voltage	U <sub>e</sub>	240 V AC
Utilization category		AC-15, U <sub>e</sub> /I <sub>e</sub> 240 V / 3 A
Direct opening action	$\bigcirc$	acc. to IEC/EN 60947-5-1, annex K
Short-circuit protective device		Fuse 10 A gG
Protection class		II, totally insulated

BERNSTEIN AG . Hans-Bernstein-Straße 1. 32457 Porta Westfalica . www.bernstein.eu

The technical datasheet corresponds to the technical state as of 2015-08-04 and will not be removed in case of changes.

## **Technical Data**



Mechanical data	
Enclosure	Thermoplastic, glass fibre reinforced
Cover	Thermoplastic, glass fibre reinforced
Actuator	Lever arm housing, lever (st), roller (thermoplastic)
Ambient air temperature	-30° C +80° C
Contact type	1 NC, 1 NO (Zb)
Mechanical life	10 x 10 <sup>6</sup> operating cycles
Switching frequency	≤ 100 / min.
Assembly	2 x M4 / 2 x M5 / 2 x M3 front mounting
Connection	4 screw connections (M3,5)
Conductor cross-sections	Solid: 0,5 1,5 mm² or Litz wire with ferrules: 0,5 1,5 mm²
Cable entrance	2 x M16 x 1,5
Weight	≈ 0,12 kg
Installation position	operator definable
Protection type	IP65 acc. to IEC/EN 60529

## ID for safety engineering

B10d

20 x 10<sup>6</sup> switching cycles

#### Actuation

The actuating device is preferably started from 2 sides.

By loosening the 4 screws the actuation assembly can be rotated in 90 degree increments such that 8 actuation directions are possible.

The actuation assembly is to be again fastened to the housing using the 4 screws.

Standards	
VDE 0660 T100, DIN EN 60947-1, IEC 60947-1	
VDE 0660 T200, DIN EN 60947-5-1, IEC 60947-5-1	
DIN EN ISO 13849-1	

### **EU Conformity**

acc. to directive 2006/95/EC

Approvals

<sub>c</sub>CSA<sub>US</sub> A300, Q300

### Notes

The degree of protection (IP code) specified applies solely to a property closed cover and the use of an equivalent cable gland with adequate cable.